



Republic of the Philippines
DEPARTMENT OF AGRICULTURE
 Regional Field Office 13
 Capitol Site Butuan City 8600

September 23, 2024

SUPPLEMENTAL BID BULLETIN NO. 2024- 067

This is to inform **ALL PROSPECTIVE BIDDERS** that the Invitation to Bid posted last September 12, 2024 for the Procurement of Various Office Equipment under Reference No. 11241229 with a total ABC of **One Million Three Hundred Twelve Thousand Eight Hundred Pesos Only (₱ 1,312,803.00)** has the following amendments:

Bid Document	Supplemental
<p>● I. Section II Bid Data Sheet ITB Clause 5.3</p> <p>Contracts similar to the project – Drugs and Biologics</p> <p>● II. Section VII. Technical Specifications:</p> <p>Item No. 1 - 12 unit Aircondition Split Type:</p> <p>-Compressor type: inverter</p> <p>-Refrigerant: R32</p> <p>-Cooling Capacity: Min. of 27,000 kj/h</p> <p>-HP rating: 2.5 HP</p> <p>-Auto Cleaning: Yes</p> <p>-EER (DOE): Min of 4.5</p> <p>-With installation (labor and materials)</p> <p>Item No. 3 - 2 units Aircondition Floor Standing:</p> <p>-Compressor type: inverter</p> <p>-Dehumidification: Yes</p> <p>-Refrigerant: R32</p> <p>-Cooling Capacity: Min. of 29,000 Kj/h</p> <p>-HP rating: 3.0 HP</p> <p>-Auto Cleaning: Yes</p> <p>-With installation (labor and materials)</p>	<p>● I. Section II Bid Data Sheet ITB Clause 5.3</p> <p>Contracts similar to the project – Office Equipment</p> <p>● II. Section VII. Technical Specifications:</p> <p>Item No. 1 - 12 unit Aircondition Split Type:</p> <p>-Compressor type: inverter</p> <p>-Refrigerant: R32</p> <p>-Cooling Capacity: Min. of 23,000 kj/h</p> <p>-HP rating: 2.5 HP</p> <p>-Auto Cleaning: Yes</p> <p>-EER (DOE): Min of 4.5</p> <p>-With installation (labor and materials)</p> <p>Item No. 3 - 2 units Aircondition Floor Standing:</p> <p>-Compressor type: inverter</p> <p>-Dehumidification: Yes</p> <p>-Refrigerant: R32</p> <p>-Cooling Capacity: Min. of 29,000 Kj/h</p> <p>-HP rating: 3.0 HP</p> <p>-Auto Cleaning: Yes</p> <p>-With installation (labor and materials)</p> <p>- EER(DOE) - Min. of 4.5</p>

	<p><i>Clarifications on the terms used;</i></p> <p><i>Energy Efficiency Ratio (EER) DOE Energy Label;</i></p> <p><i>Energy Efficiency Factor (EEF) DOE Energy Label</i></p>
--	---

This supplemental bid bulletin shall be posted at the DA-Caraga and PhilGEPS official websites and at the Office Bulletin Board for the information and guidance of all interested parties and shall form as an integral part of the Bid Documents for the said project.


ABEL F. WAGAS
BAC Chairperson

